

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-0476:119 Page 1 of 1

CATEGORY: Pull Station/Boxes

LISTEE: Harrington Signal Inc., 2519 4th Avenue, Moline, IL 61265
Contact: Andrew Keller (309) 762-0731

DESIGN: Model 4050-001T through -005T, -051T through -055T, -101T through -105T, -211T, -212T, -223T through -225T, -271T through -275T, -321T through -325T, -402T, -403T, -406T, -409T, -413T through -416T manual pull stations. Unit may be followed by an additional three-digit suffix for color designation. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number, electrical rating and UL label.

APPROVAL: Listed as manual pull stations for use with separately listed compatible fire alarm control units. All units shall be mounted on a listed outlet box or Models 9090-006, -007 or 4050BB back box. For indoor use only.

NOTE: Formerly 7150-0811:115

10-08-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 9, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager